

 राज्य सार्वजनिक आरोग्य विभाग महाराष्ट्र सरकार	 STATE PUBLIC HEALTH LABORATORY, PUNE	 NATIONAL HEALTH MISSION MAHARASHTRA NHM राष्ट्रीय आरोग्य मिशन महाराष्ट्र	
Dy Director tele No. Office Tele No.	26330509 (P) 26330225 (O)	Cantonment water works campus, Near Saint Mary Church, Staveley road, Pulgate, Pune-411 001 (MH) INDIA Email ID : sphlmis@gmail.com , statehealthlab@gmail.com website : arogya.maharashtra.gov.in	
HEALTH SERVICES:	No.SPHLPUNE/Desk-80/Bact.Section/water analysis report/ <u>2932</u> / 2026 Date : <u>05/03</u> / 2026		

Bacteriological Report of water Sample

Sender's Name	Principal, Gladiolus English Medium School, Gat No. 599/1, Ekta nagar, Chakan, Tal.- Khed, Dist.- Pune -410501
Sender's letter No. & date	81 / 27-02-2026
Lab. Reference No.	248 / 1763
Date of sample collection	02-03-2026
Date of sample received	02-03-2026
Analysis start date	02-03-2026

Sample Description	Bacteriological Analysis result			
	Most Probable Number of bacteria found per 100 ml of Water Sample			
	Coliforms	Thermotolerant Coliforms	E.coli	Conclusion
1. , Gladiolus English Medium School, Ektanagar, Chakan - RO (Borewell) Water	0	-	-	Potable

Remark: If water sample found non-potable, it can be used for drinking purposes after proper treatment and ascertaining its bacteriological quality for potability by retesting.

Note: Above sample/samples is/are not collected by this laboratory and result is/are as per submitted sample/samples.


Fee Rs. : 340/-


Receipt No. : 7763057

Date : 27-02-2026

V.P. Abhyankar
PRINCIPAL

Gladiolus English Medium School
Ektanagar, Chakan, Pune 410501


C.S.P. Sandhaney
Chief Bacteriologist
State Public Health Laboratory, Pune


MANAGER
Gladiolus English Medium School
Ektanagar, Chakan, Pune - 410501